

---

## SSNL117 - Bend in bending in elastoplasticity

---

### Summarized:

This test validates the modelization of the phenomena of ovalization in the pipework in the elastoplastic field with the elements PIPE: an elbow, prolonged by right pipes is subjected to a bending in its plane. The pipework is thick (of size similar to the elbows of the primary education circuits). The reference solution is numerical: it is obtained with *Code\_Aster* using a mesh 3D of the elbow.


The two modelizations make it possible to validate A the elements PIPE (with right and bent elements with 3 nodes for the modelization and of the right and bent elements with 4 nodes for the modelization B) in elastoplasticity.

Into the modelization B, a term of "total" rotation, developed by EDF, French atomic energy agency and FRAMATOME [bib2], for the pipework under seisme, is introduced via a macro-command Python.

## 1 Problem of reference

### 1.1 Geometry

Pipework bent in the plane  $XY$ . The right parts have as a length  $L = 1\text{ m}$ .  
The elbow has as a radius of curvature:  $R_c = 1.25\text{ m}$



The tubular section has for average radius  $R = 395.5\text{ mm}$  and a thickness  $e = 77\text{ mm}$ .

### 1.2 Properties of the materials

the material is elastoplastic with isotropic linear hardening.

$$E = 2.E11\text{ Pa}$$

$$\nu = 0.3$$

Elastic limit  $SIGY = 200.10^6\text{ Pa}$

Hardening modulus  $D\_SIGM\_EPSI = 2.10^{10}\text{ Pa}$

### 1.3 Boundary conditions and loadings

Fixed support in  $A$  (degrees of freedom of beam blocked, but free degrees of freedom of ovalization).

Moment  $MZ$  imposed while  $D$  growing:

Increment 1  $Mz = 3086702.1520853\text{ Nm}$

10 equal increments until:

Increment 11  $Mz = 7091146.5935484\text{ Nm}$

### 1.4 Initial conditions

Without object.

## 2 Reference solution

### 2.1 Method of calculating used for the reference solution

Comparison to other numerical results got with *Code\_Aster* (version 4.3 [bib1]) with a mesh 3D of the elbow and right parts, connected at the ends with straight beams. This mesh 3D comprises 1024 meshes HEXA20. A modelization of the elbow in elements COQUE\_3D gave results comparable to computation 3D (see [§2.2]).

### 2.2 Results of reference

For one applied moment  $M_z$  in  $D$ , the displacement  $DY$  of the same point  $D$  is worth [bib1]:

| Moment      | $Dy$ not $D$ (m) (3D) | $Dy$ not $D$ (m) (COQUE_3D) |
|-------------|-----------------------|-----------------------------|
| 0.          | 0.                    | 0.                          |
| 3.08670D+06 | 1.09349D-02           | 1.08875D-02                 |
| 3.48715D+06 | 1.23536D-02           |                             |
| 3.88759D+06 | 1.37891D-02           | 1.37381D-02                 |
| 4.28804D+06 | 1.52727D-02           |                             |
| 4.68848D+06 | 1.68128D-02           |                             |
| 5.08892D+06 | 1.84085D-02           |                             |
| 5.48937D+06 | 2.01272D-02           |                             |
| 5.88981D+06 | 2.20836D-02           |                             |
| 6.29026D+06 | 2.43502D-02           |                             |
| 6.69070D+06 | 2.70438D-02           |                             |
| 7.09115D+06 | 3.04756D-02           |                             |

### 2.3 Accuracy on the results of reference

Owing to the fact that the reference solution is numerical, one can evaluate the accuracy according to [§2.2] with 2% by comparison of the solutions 3D and COQUE\_3D.

### 2.4 References bibliographical

- [1] J.M. PROIX, A. BEN HAJ YEDDER: "Project CACIP: study of a pipework bent in bending". Note EDF/DER HI-75/98/001/0
- [] C. CHURN (SEPTEN), MN. BERTON, N. BLAY (FRENCH ATOMIC ENERGY AGENCY), F. LE BRETON (FRAMATOME - ANP): "Project of new coding of the criteria of seismic design of the pipework". Note EDF/SEPTEN E-N-ES-MS/01-01004-A.

## 3 Modelization A

---

### 3.1 Characteristic of the modelization

the structure is with a grid in elements pipes (meshes SEG3, modelization PIPE).

### 3.2 Characteristics of the mesh

20 meshes SEG3 (The mesh are regular: 10 elements in the elbow, 5 in each right pipe)

### 3.3 Quantities tested and Increment

| results of load         | $DY$ of the point<br>$D$ | Reference   | % difference |
|-------------------------|--------------------------|-------------|--------------|
| 1: $Mz = 3.08670D+06Nm$ | $DY$ (m)                 | 1.09349E-02 | 2.3          |
| 8: $Mz = 5.88981D+06Nm$ | $DY$ (m)                 | 2.20836E-02 | 2.75         |

## 4 Modelization B

### 4.1 Characteristic of the modelization

the structure is with a grid in elements pipes with 4 nodes (meshes SEG4, modelization PIPE).

### 4.2 Characteristics of the mesh

11 meshes SEG4 (5 elements in the elbow, 3 in each right pipe)

### 4.3 Computation of the term of "Total" Rotation

This term of "total" rotation were developed in the frame of a tripartite action EDF - French atomic energy agency - FRAMATOME [bib2], for a future integration in the code of design RCC-M. It is expressed starting from rotations of two points representative of the elbow (entered and left), by:

$$R_G = \sqrt{\Delta R_x^2 + \Delta R_y^2 + \Delta R_z^2}$$

where

$$\Delta R_x = DRX_{sortiecoude} - DRX_{entreecoude}$$

$$\Delta R_y = DRY_{sortiecoude} - DRY_{entreecoude}$$

$$\Delta R_z = DRZ_{sortiecoude} - DRZ_{entreecoude}$$

This term is calculated by the macro-command Python MACR\_ROTA\_GLOBALE which is integrated in the body of the command file. Result of this macro-command is a function Aster of total rotation according to time. A test of NON-regression comes to validate this function.

### 4.4 Quantities tested and Increment

| results of load           | DY of the point<br>D | Reference   | % difference |
|---------------------------|----------------------|-------------|--------------|
| 1: $Mz = 3.08670D + 06Nm$ | DY (m)               | 1.09349D-02 | 0.3          |
| 8: $Mz = 5.88981D + 06Nm$ | DY (m)               | 2.20836D-02 | 1.1          |

Test of NON-regression for total rotation:

| Urgent      | Aster       |
|-------------|-------------|
| 5.88981E+06 | 9.26451E-03 |

Tests of non regression for the options of CALC\_CHAMP or POST\_CHAMP :

| Component | option | Does not net | Subpoint | Sequenc<br>ce<br>number | Aster |                 |
|-----------|--------|--------------|----------|-------------------------|-------|-----------------|
| SIEQ_ELGA | VMIS   | M1           | 2        | 61                      | 1     | 4.675554583E+07 |
| SIEQ_ELGA | VMIS   | M1           | 3        | 55                      | 3     | 5.608141169E+07 |
| EPEQ_ELGA | INVA_2 | M1           | 1        | 77                      | 4     | 2.590281477E-04 |
| EPEQ_ELGA | INVA_2 | M1           | 1        | 8                       | 5     | 1.769279362E-04 |

| Component | Component | Option | Does<br>not net | Sequen<br>ce<br>number | Aster       |             |
|-----------|-----------|--------|-----------------|------------------------|-------------|-------------|
| SIEQ_ELGA | VMIS/MAX  | VAL    | M1              | 1                      | 8.84099E+07 |             |
| SIEQ_ELGA | VMIS/MIN  | VAL    | M1              | 1                      | 5.88318E+06 |             |
| SIEQ_ELGA | VMIS/MAX  | NUCOU  | m2              | 2                      | 1.00000E+00 |             |
| SIEQ_ELGA | VMIS/MIN  | NUCOU  | m3              | 3                      | 1.00000E+00 |             |
| SIEQ_ELGA | VMIS/MAX  | NUSECT | M4              | 1                      | 1.20000E+01 |             |
| SIEQ_ELGA | VMIS/MIN  | NUSECT | M5              | 2                      | 1.60000E+01 |             |
| SIEQ_ELGA | VMIS/MAX  | POSIC  | M6              | 3                      | 1.00000E+00 |             |
| SIEQ_ELGA | VMIS/MIN  | POSIC  | M7              | 1                      | 2.00000E+00 |             |
| SIEQ_ELGA | VMIS/MAX  | POSIS  | M8              | 2                      | 3.00000E+00 |             |
| SIEQ_ELGA | VMIS/MIN  | POSIS  | M9              | 3                      | 3.00000E+00 |             |
| SIEQ_ELGA | VMIS/MAX  | VAL    | M1              | 2                      | 4           | 1.27695E+08 |
| SIEQ_ELGA | VMIS/MIN  | VAL    | M5              | 3                      | 5           | 2.20755E+07 |

## 5 Summary of the results

---

the reference solution not being analytical, but numerical (obtained by a modelization 3D), the noted variations (of 1% with 3% ) can be regarded as reasonable. 3D to obtain a better correspondence of the solutions and PIPE, it would be advisable to model the right parts over a bigger length, and to adopt a finer mesh for each modelization. This was not done in the frame of this test, to keep reasonable execution times.